

**YAHOO!** SMALL BUSINESS

RE: Revised Dwgs.- Atlantic Ave Tunnel  
From: "Berenblit, Emma" <eberenblit@dot.nyc.gov>  
To: "Robert Diamond" <rdiamond@brooklynrail.net>

Friday, August 14, 2009 9:34 AM

Bob

OCMC has no further comments.

---

**From:** Robert Diamond [mailto:rdiamond@brooklynrail.net]  
**Sent:** Thursday, August 13, 2009 1:59 PM  
**To:** Berenblit, Emma  
**Subject:** Revised Dwgs.- Atlantic Ave Tunnel

Hi Emma, attached are the revised drawings MPT-4 and MPT-5. The Consultant advises that once there are no further comments, he will sign and stamp the 4 originals.

Thanks,  
Bob

---

**From:** "Berenblit, Emma" <eberenblit@dot.nyc.gov>  
**To:** Robert Diamond <rdiamond@brooklynrail.net>  
**Sent:** Thursday, August 13, 2009 12:36:19 PM  
**Subject:** RE: Metal Barricades No Good- Atlantic Ave Tunnel

Thanks

---

**From:** Robert Diamond [mailto:rdiamond@brooklynrail.net]  
**Sent:** Thursday, August 13, 2009 12:36 PM  
**To:** Berenblit, Emma  
**Subject:** Re: Metal Barricades No Good- Atlantic Ave Tunnel

OK thanks, not a problem. I expect the drawings will be modified today.

Thanks  
Bob

---

**From:** "Berenblit, Emma" <eberenblit@dot.nyc.gov>  
**To:** Robert Diamond <rdiamond@brooklynrail.net>  
**Sent:** Thursday, August 13, 2009 11:26:46 AM  
**Subject:** RE: Metal Barricades No Good- Atlantic Ave Tunnel

As per OCMC:

You do need to extend the barricades you show on the drawing to go from the crosswalk area up to the protection vehicle.

---

**From:** Robert Diamond [mailto:rdiamond@brooklynrail.net]  
**Sent:** Wednesday, August 12, 2009 7:27 PM  
**To:** Berenblit, Emma  
**Subject:** Metal Barricades No Good- Atlantic Ave Tunnel

Hi Emma, the following is the Consultant's response regarding OCMC's comments on metal parade barricades, please pass it on to the appropriate people:

Bob,

Metal Barricades are not in compliance with the MUTCD and is considered as a hazard to be placed in the work protection zone. We cannot comply with the City's comments in this regard due to the liability standpoint.

Regards,  
Akhlq

---

**From:** "Berenblit, Emma" <eberenblit@dot.nyc.gov>  
**To:** Robert Diamond <rdiamond@brooklynrail.net>  
**Sent:** Wednesday, August 12, 2009 4:51:00 PM  
**Subject:** FW: MTP Plan- Atlantic Ave Tunnel

FYI. Please respond. Thanks

---

**From:** Noto, Joe  
**Sent:** Wednesday, August 12, 2009 2:03 PM  
**To:** Berenblit, Emma  
**Cc:** Esposito, Franco; Jaber, Jay ; Puccio, Frank  
**Subject:** FW: MTP Plan- Atlantic Ave Tunnel

Emma, see ocmc's comments as it relates to the drawings..